

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	78 - FraserCascade
<b>School Name:</b>	Boston Bar elm/sec
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2022-06-29
	Date of next inspection: 2022-10-28
	Date and type of most recent maintenance: June 29 filter change
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Increase % intake of outside air and auto ventilate
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Merv 13
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: Yes
	Caspr ultra violet light in Building ventilation ducts
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Manage with esc building automation
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: D Templeton
	Phone Number: 604-869-2411
	Email: doug.templeton@sd78.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	78 - FraserCascade
<b>School Name:</b>	Hope elm/sec
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2022-06-29
	Date of next inspection: 2022-10-28
	Date and type of most recent maintenance: June 29 filter change
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Increase % intake of outside air and auto ventilate
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Merv 13
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: Yes
	Caspr ultra violet light in Building ventilation ducts
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Manage with esc building automation
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: D Templeton
	Phone Number: 604-869-2411
	Email: doug.templeton@sd78.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	78 - FraserCascade
<b>School Name:</b>	Harrison Hot Springs Elm
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2022-06-29
	Date of next inspection: 2022-10-28
	Date and type of most recent maintenance: June 29 filter change
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Increase % intake of outside air and auto ventilate
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Merv 13
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Manage with auto stats and monitor with esc building automation
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: D Templeton
	Phone Number: 604-869-2411
	Email: doug.templeton@sd78.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	78 - FraserCascade
<b>School Name:</b>	Agassiz Elm/Sec
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2022-06-29
	Date of next inspection: 2022-10-28
	Date and type of most recent maintenance: June 29 filter change
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Increase % intake of outside air and auto ventilate
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Merv 13
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Manage with esc building automation
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: D Templeton
	Phone Number: 604-869-2411
	Email: doug.templeton@sd78.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	78 - FraserCascade
<b>School Name:</b>	Coquihalla Elm
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2022-06-29
	Date of next inspection: 2022-10-28
	Date and type of most recent maintenance: June 29 filter change
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Increase % intake of outside air and auto ventilate
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Merv 13
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: Yes
	Caspr ultra violet light in Building ventilation ducts
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Manage with esc building automation
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: D Templeton
	Phone Number: 604-869-2411
	Email: doug.templeton@sd78.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	78 - FraserCascade
<b>School Name:</b>	Kent Elm
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2022-06-29
	Date of next inspection: 2022-10-29
	Date and type of most recent maintenance: June 29 filter change
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Increase % intake of outside air and auto ventilate
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Merv 13
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: Yes
	Detail: Capr Ultra violet lights in unit ventilators
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Manage with esc building automation
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: D Templeton
	Phone Number: 604-869-2411
	Email: doug.templeton@sd78.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	78 - FraserCascade
<b>School Name:</b>	Silver Creek Elm
<b>REQUIREMENT:</b> Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2022-06-29
	Date of next inspection: 2022-10-28
	Date and type of most recent maintenance: June 29 filter change
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes
	Detail: Increase % intake of outside air and auto ventilate
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Merv 13
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: Yes
	Caspr ultra violet light in Building ventilation ducts
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Manage with esc building automation
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: D Templeton
	Phone Number: 604-869-2411
	Email: doug.templeton@sd78.bc.ca